

Certificate of Compliance

Certificate Number **170409-E328705**
Report Reference **E328705, July 16, 2007**
Issue Date **2009 April 17**

Page 1 of 1



Issued to:

ETK Kablo San Tic A S

Osman Gazi Mah Bilali Habesi Cad
Samandira
Istanbul, 135
Turkey

*This is to certify that
representative samples of*

Communications Cable
Types CM and CMR

*Have been investigated by Underwriters Laboratories in accordance with
the Standard(s) indicated on this Certificate.*


Standard(s) for Safety:

Evaluated in accordance with the Bi-National Standard for Communications
Cables, UL 444/CSA C22.2 No. 214

Additional Information:

Rated 60 or 75 degrees C.

Only those products bearing the UL Listing Mark for the US and Canada should be considered as being covered by UL's Listing and Follow-Up Service meeting the appropriate requirements for US and Canada.

The UL Listing Mark for the US and Canada generally includes: the UL in a circle symbol with "C" and "US" identifiers:  the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product

Issued by: *Bose Francois*

Bose Francois, Project Engineer

Underwriters Laboratories Inc.

Reviewed by: *Robert W. Bellassai*

Robert W. Bellassai, Staff Engineer

Underwriters Laboratories Inc.

Any information and documentation involving UL Mark services are provided on behalf of Underwriters Laboratories Inc. (UL) or any authorized licensee of UL.
For questions in The United States of America you may call 1-877-UL-HELPS.