METCAB UYGUNLUK DEĞERLENDİRME LTD. ŞTİ.
METCAB CONFORMITY ASSESSMENT BODY

AB-0225-U

CERTIFICATE OF CONSTANCY OF PERFORMANCE

3130-CPR-001

In compliance with Regulation (EU) 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Cable type : HSLHCH JZ/OZ/JB/OB

Reaction to fire class : $B2_{ca}$-s1a, d1, a1

Cables used in buildings and other civil engineering works with the objective of limiting the generation and spread of fire and smoke

placed on the market under the name or trade mark of

ETK KABLO SANAYİ VE TİCARET A.Ş.

OSMANGAZİ MAH. MÜSTESNA SOK. NO:37 SAMANDIRA, SANCAKTEPE/İSTANBUL

and produced in the manufacturing plant

ETK KABLO SANAYİ VE TİCARET A.Ş.

OSMANGAZİ MAH. MÜSTESNA SOK. NO:37 SAMANDIRA, SANCAKTEPE/İSTANBUL

EN 50575: 2014 + A1: 2016

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s) under system 1+ for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product .

This certificate was first issued on 29.12.2025 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

Ankara, 29.12.2025, Rev. 0

NB:3130

Technical Manager
Ersin Gök

This document shall not be altered or modified in any manner and shall not be reproduced in a way that affects its legibility.

PRODUCT DESCRIPTION:

Type designation of the cable family	HSLHCH JZ/OZ/JB/OB

DESIGN INFORMATION:

Conductor design	Round
Conductor class	5
Conductor type	Copper
Number of cores	Multi cores
Armor	Includes

EXTENDED APPLICATION ACCORDING TO ELECTRICAL CABLES – REACTION TO FIRE RESULTS - *EN 50576*:

Scope
☒Armored
☐Unarmored multicore
☐Single core, sheated
☐Single core, unsheated
☐Cable family includes cores with diameter ≤ 5 mm

CROSS-SECTIONS COVERED:

Number of cores	Cross-section mm²
2 to 37	0,50 to 16

CABLE PARAMETER RANGE

χ = 12-225

OUTER DIAMETER RANGE

D = 6,6 mm- 36,6 mm

Metcab Uygunluk Değerlendirme Limited Şirketi - Metcab Conformity Assessment Body
NB:3130

This is the Annex to the Certificate of Constancy of Performance No. 3130-CPR-001.

This document shall not be altered or modified in any manner and shall not be reproduced in a way that affects its legibility.