



TÜRK STANDARDLARI ENSTİTÜSÜ
TURKISH STANDARDS INSTITUTION



Test
TS EN ISO/IEC 17025
AB-0001-T




353663

TSE DENEY VE KALİBRASYON MERKEZİ BAŞKANLIĞI
ELEKTROTEKNİK LABORATUVARI GEBZE MÜDÜRLÜĞÜ
HEADSHIP OF TSE TEST AND CALIBRATION CENTER
ELECTROTECHNICAL LABORATORY GEBZE DIRECTORATE

**CLASSIFICATION OF REACTION TO FIRE
FOR ELECTRIC CABLES
IN ACCORDANCE WITH EN 13501-6**

Sponsor	:	ETK KABLO SAN. TİC. A.Ş.
Trade mark	:	ETK CABLE
Model	:	JUMPER WIRE 2x0.6 mm
Product description	:	Copper Wire , PVC Insulation ,Twisted Pair
Standard applied	:	TS EN 50575/A1:2016
Regulation	:	Construction Products Regulation (305/2011/EU)
Laboratory	:	Electrotechnical Laboratory Gebze Directorate
Notified Body No	:	1783
Date of Issue	:	04.08.2017

Reaction to Fire Class: *Eca*

	<i>Person in charge of tests</i>	<i>Approved by</i>
07/08/2017	 Ayhan UÇAR Expert	 Hilmi AKDOĞAN Laboratory Director

Note: This classification document does not represent type approval or certification of the product. The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation. The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested. This document consists of 2 pages. This report can't be partially copied and the unsigned copies are invalid.

TS EN 13501-6 04.2014
LAB-D-2- FR-24 28.06.2017 Rev.0

1/2

www.tse.org.tr / Necatibey Cad. No: 112 Bakanlıklar - ANKARA / +90 312 416 62 00

Bu belge hiçbir suretle tahrif edilemez, kısmen veya okunmasını zorlaştıracak şekilde çoğaltılamaz, kazınır ve silinti yapılamaz.
This certificate cannot be altered, partially duplicated or erased for misunderstanding.



1- Introduction

This classification report defines the classification of cable below in accordance with the procedures given in TS EN 13501-6

2- Details of classified product

Sponsor	ETK KABLO SAN. TİC. A.Ş.	
Manufacturer (if different)		
Place of Manufacturer	Osmangazi Mah. Müstesna Sok. No:37 Samandıra/İSTANBUL	
Sample description		
Trade name, Type of cable	ETK CABLE, JUMPER WIRE 2x0.6 mm	
Sample description	Copper Wire , PVC Insulation , Twisted Pair	
Tested cable and X parameter	Jumper Wire 2x0.6mm	Xmin: -- Xmax: --

3- Test Reports in support of this classification

Enter details of reports here as applicable

Number	Test reports no and Date	Test methods
1	353662 / 08-17	TS EN 50575/A1: 2016 - TS EN 60332-1-2/A11:2017

4- Classification and field of application

The format of the reaction to fire classification for electric cables is:

Fire Behaviour	Smoke Production	Flaming Droplets	Acidity
E_{ca}	--	--	--

Reaction to Fire Classification: **E_{ca}**

5- Field of Application

This classification is valid for the power cables listed below as determined in the extended application process according to CLC-FprTS 50576-2016.

Trade name	Cable Family	Description	Reaction to Fire Classification
ETK CABLE	JUMPER WIRE	2x0.6mm	E_{ca}

