



TÜRKAK - TÜRK AKREDİTASYON KURUMU tarafından akredite  
Accredited by TÜRKAK

**TSE DENEY ve KALİBRASYON MERKEZİ BAŞKANLIĞI**  
**Elektroteknik ve Kimya Laboratuvarları Grup Başkanlığı**  
**Elektroteknik Laboratuvarı Gebze Müdürlüğü**

Adres:TSE Kalite Kampüsü Cumhuriyet Mah. 2258 Sk. No:10 H-Blok, Çayırova Tren İstasyonu Yanı Gebze/ KOCAELİ  
Tel:+90 (262) 723 1506 Fax: +90 (262) 723 16 20 E-posta:elektrotekniklab@tse.org.tr Web:www.tse.org.tr

HEADSHIP OF TSE TEST and CALIBRATION CENTER  
ELECTROTECHNICAL LABORATORY (GEBZE)

Address:TSE Kalite Kampüsü Cumhuriyet Mah. 2258 Sk. No:10 H-Blok, Çayırova Tren İstasyonu Yanı Gebze/ KOCAELİ  
Tel:+90 (262) 723 1506 Fax: +90 (262) 723 16 20 E-mail:elektrotekniklab@tse.org.tr Web:www.tse.org.tr

**MUAYENE VE DENEY RAPORU**  
**TEST REPORT**



Test  
TS EN ISO/IEC 17025  
AB-0001-T

AB-0001-T

345581

06-17

**Deneyi Talep Eden** : ETK KABLO SAN.VE.TİC.A.Ş.  
(Adı,Adresi,Şehir vb.)  
*Customer (Name,Address,City etc.)*

**Deney Talep Tarihi/No** : 05.06.2017 / 180541  
*Order Date / No*

**Numunenin Tanımı** : KABLO, ETK KABLO , VBV (JYY) , - , - , 2,00 metre  
(Cins, Marka, Tip, Tür, Model vb.)  
*Sample Description(Type,Mark,Model etc.)*

**Numune Kabul Tarihi** : 05.06.2017  
*Test Item Receipt Date*

**Deneylerin Yapıldığı Tarih** : 06.06.2017 - 08.06.2017  
*Date of Test*

**Uygulanan Standard / Metod** : TS EN 13501-6:2014-04 Yapı mamulleri ve yapı elemanları - Yangın sınıflandırması - Bölüm 6: Elektrik kablolarındaki yangın deneylerinin reaksiyonlarından elde edilen veriler kullanılarak sınıflandırma  
*Applied Standard/Method*

**Raporun Sayfa Sayısı** : 4  
*Number of pages of the report*

**Açıklamalar** :  
*Remarks*

Türk Akreditasyon Kurumu(TÜRKAK) deney raporlarının tanınması konusunda Avrupa Akreditasyon Birliği(EA) ve Uluslararası Laboratuvar Akreditasyon Birliği(ILAC) ile karşılıklı tanınma antlaşmasını imzalamıştır.  
*The Turkish Accreditation Agency(TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation(EA) and of the International Laboratory Accreditation(ILAC) for the Mutual recognition of test reports.*  
Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metodları bu raporun tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.  
*The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.*



**Tarih**  
*Date*

05.06.17

**Deney Sorumlusu**  
*Person in charge of tests*

Ensar GEDİKOĞLU  
Tekniker

**Kontrol Eden**  
*Reviewer*

Metinmet YAZICI  
Teknik Şef

**Onaylayan**  
*Approved by*

Hilmi AKDOĞAN  
Laboratuvar Müdürü

Bu rapor, hazırlayan laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mührsüz raporlar geçersizdir.

Bu rapor, sadece deneyi yapılan numune için geçerlidir ve "Ürün Belgesi" yerine geçmez.

*This test report shall not be reproduced other than in full except with the written permission of the laboratory. Test reports without signature and seal are not valid.*

*This test report represents only tested sample(s), and shall not be used as Product Certificate*



## REACTION TO FIRE CLASSIFICATION OF ELECTRICAL CABLES

### 1-Introduction

This classification report defines the classification assigned to ETK CABLE – VBV (J-YY) in accordance with the procedures given in TS EN 13501-6



### CLASSIFICATION OF REACTION TO FIRE FOR ELECTRIC CABLES IN ACCORDANCE WITH TS EN 13501-6

<b>Sponsor</b>	ETK KABLO SAN. VE TİC. A. Ş.
<b>Prepared by</b>	TSE Elektroteknik Laboratuvarı Gebze Müdürlüğü
<b>Notified Body No</b>	1783
<b>Product name</b>	ETK CABLE with trade mark, ETK CABLE – VBV (J-YY) type of cable
<b>Classification report No</b>	345581/06-17
<b>Issue number</b>	2
<b>Issue date</b>	08.06.2017

This classification report consists of 4 pages and may only be used or reproduced in its entirety.

### 2 Details of classified product

#### 2.1 General

ETK CABLE with trade mark, ETK CABLE – VBV (J-YY) type of cable

#### 2.2 Product description

ETK CABLE with trade mark, ETK CABLE – VBV (J-YY) type of cable is described below.

<b>Sponsor</b>	ETK KABLO SAN. VE TİC. A. Ş.
<b>Manufacturer</b>	ETK KABLO SAN. VE TİC. A. Ş.
<b>Place of manufacturer</b>	Osmangazi Mah. Müstesna sok. No:37 Samandıra-Sancaktepe / İstanbul
<b>Trade name</b>	ETK CABLE, ETK CABLE – VBV (J-YY)
<b>Sample description</b>	Class 1 conductor
<b>Tested cable and size</b>	1- VBV (J-YY) 1x2x0,50mm <sup>2</sup> 2- VBV (J-YY) 100x2x0,50mm <sup>2</sup>
<b>Overall diameter</b>	1- VBV (J-YY) 1x2x0,50mm <sup>2</sup> =3,10 2- VBV (J-YY) 100x2x0,50mm <sup>2</sup> =19,61





### 3 Reports and results in support of this classification

#### 3.1 Reports

Enter details of reports here as applicable

Name of Laboratory	Name of Sponsor	Test Reports No	Test method
TSE Gebze Electrotechnical Laboratory	ETK KABLO SAN. VE TİC. A. Ş.	345559/ 06-17	TS EN 60332-1-2/A11:2017
TSE Gebze Electrotechnical Laboratory	ETK KABLO SAN. VE TİC. A. Ş.	345558/ 06-17	TS EN 60332-1-2/A11:2017

#### 3.2 Results

Test method and type of cable	Parameter	No. of test	Test results	
			Continuous parameter	Compliance with parameters
VBV (J-YY) 1x2x0,50mm <sup>2</sup> TS EN 60332-1-2/A11:2017	H (Vertical flame spread)	1	200 mm	≤ 425mm / Eca
VBV (J-YY) 100x2x0,50mm <sup>2</sup> TS EN 60332-1-2/A11:2017	H (Vertical flame spread)	1	120 mm	≤ 425mm / Eca

### 4 Classification and field of application

#### 4.1 Reference of Classification

This classification has been carried out in accordance with TS EN 13501-6:2014.

#### 4.2 Classification

The power cables in relation to reaction to fire behaviour are classified:

**E<sub>ca</sub>**

The format of the reaction to fire classification for electric cables is:

Fire Behaviour	Smoke Production	Flaming Droplets	Acidity
<b>E<sub>ca</sub></b>	-	-	-

**Reaction to Fire Classification: E<sub>ca</sub>**





### 4.3 Field of application

This classification is valid for the power cables listed below as determined in the extended application process according to CLC-FprTS 50576-2016.

Brand name	Cable Family	Outer diameter of cable	Reaction to Fire Classification
ETK CABLE	VBV (J- YY)	3,036 mm to 24,47 mm	E <sub>ca</sub>

### 5 Limitations

This classification document does not represent type approval or certification of the product.

The classification assigned to the product in this report is appropriate to a declaration of conformity by the manufacturer within the context of system 3 attestation of conformity and CE marking under the Construction Products Regulation.

The test laboratory has, therefore, played no part in sampling the product for the test, although it holds appropriate references, supplied by the manufacturer, to provide for traceability of the samples tested

Signed

ENSAR GEDİKOĞLU

Technician

Electrotechnical Laboratory

Approved

Hilmi AKDOĞAN

Director of Electrotechnical

Laboratory

